

CITY OF MOUNTAIN VIEW

Maintenance Department  
(415) 966-6327

231 No. Whisman Road  
P. O. Box 10  
Mountain View, CA 94042

April 5, 1983

Mr. Lee Coward, Facilities Manager  
Raytheon Semiconductor  
350 Ellis Street  
Mountain View, CA 94043

INDUSTRIAL WASTE DISCHARGE VIOLATIONS

Dear Mr. Coward:

A sampling of your company's industrial wastewater discharge was conducted by the City of Mountain View on March 16, 1983. Composite samples at the north and south discharge points showed levels of fluoride of 65 and 120 milligrams per liter, respectively. The maximum allowable concentration is 5 milligrams per liter.

This letter is to notify your company of the City's intent to enforce the discharge requirements of the Industrial Waste Ordinance, Section 35.32 through Section 35.32.21 of the City Code, a copy of which is enclosed.

Failure to achieve compliance will result in suspension or revocation of your industrial waste discharge permit and could lead to civil penalties of up to \$6,000 per day. In addition, on July 1, 1983, notice shall be provided to the San Jose Mercury and Peninsula Times-Tribune if any violation remains uncorrected 45 days after this notification.

Please submit self-monitoring reports to me which cover at least one typical full day of operation each week. Analyses of fluoride must be made on a composite of equal-sized samples collected at each discharge point during each hour of operation. The weekly analyses must be performed by a laboratory certified by the State Department of Health Services and must be accompanied by a statement of an official of your company that the sampling and analyses are a true representation of the wastewater discharged from your plant during the week of sampling.

Please call me at 966-6329 if you have questions.

Sincerely,

*Norman H. Lougee*

Norman H. Lougee, Water Division Engineer

NHL/get/707-4-5L, 51  
Enclosure

cc: W. A. Chapman

CM, MD, WDE